



Ref. Certif. No.

HU-006024

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Surge Protective Device

Name and address of the applicant

Guangdong Yada Electronics Co., Ltd.
YADA Industrial Park, Gaopugang, Heyuan city 517000
Guangdong, P.R. China

Name and address of the manufacturer

Guangdong Yada Electronics Co., Ltd.
YADA Industrial Park, Gaopugang, Heyuan city 517000
Guangdong, P.R. China

Name and address of the factory

Note: When more than one factory, please report on page 2

Guangdong Yada Electronics Co., Ltd.
YADA Industrial Park, Gaopugang, Heyuan city 517000
Guangdong, P.R. China

Ratings and principal characteristics

Ucpv:1)3)5)1200V DC, 2)4)6)1000V DC; In:20kA; Imax:40kA
Up:1)3)5)4.5kV, 2)4)6)4.0kV; Itotal:40kA(8/20 μ s); Iscpv:20A
Class II; Indoor; IP20

Trademark / Brand (if any)

YADA

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

1)YDF40-1200YPV, 2)YDF40-1000YPV
3)YDF40-1200YPV FM, 4)YDF40-1000YPV FM
5)YDF40-1200YPV (FM), 6)YDF40-1000YPV (FM)

Additional information (if necessary may also be reported on page 2)

N/A

A sample of the product was tested and found to be in conformity with

IEC 61643-31:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

CN252X5Z 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2025-11-17

Signature:

Wencai Zhang