

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Surge Protective Device

Name and address of the applicant

Guangdong Yada Electronics Co., Ltd.
YADA Industrial Park, Gaopugang, Heyuan city 517000
Guangdong, P.R. China

Name and address of the manufacturer

Guangdong Yada Electronics Co., Ltd.
YADA Industrial Park, Gaopugang, Heyuan city 517000
Guangdong, P.R. China

Name and address of the factory

Note: When more than one factory, please report on page 2

Guangdong Yada Electronics Co., Ltd.
YADA Industrial Park, Gaopugang, Heyuan city 517000
Guangdong, P.R. China

Ratings and principal characteristics

Uc:1)-6) 385V AC (3+1,1+1:L-N), 255V AC (3+1,1+1:N-PE)
7)-12) 385V AC (2+0,4+0:L/N-PE)
Up:1)-6) 1.8kV (3+1,1+1:L-N), 1.5kV (3+1,1+1:N-PE)
7)-12) 1.8kV (2+0,4+0:L/N-PE)
In:20kA; I_{max}:40kA; I_{sc}:300A; Class II
IP20; Indoor; One port

Trademark / Brand (if any)

YADA

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

1) YDF40-385/3+1 (FM), 2) YDF40-385/1+1 (FM), 3) YDF40-385/3+1 FM
4) YDF40-385/1+1 FM, 5) YDF40-385/3+1, 6) YDF40-385/1+1
7) YDF40-385/2+0 (FM), 8) YDF40-385/4+0 (FM), 9) YDF40-385/2+0 FM
10) YDF40-385/4+0 FM, 11) YDF40-385/2+0, 12) YDF40-385/4+0

Additional information (if necessary may also be reported on page 2)

N/A

A sample of the product was tested and found to be in conformity with

IEC 61643-11:2011

As shown in the Test Report Ref. No. which forms part of this Certificate

CN254YC6 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2025-11-17

Signature:



Wencai Zhang